



#	QTY.	MATERIAL	DESCRIPTION
1	AS REQ.	STAINLESS STEEL 304	2" PIPE (.065 WALL) 180 GRIT
2	AS REQ.	STAINLESS STEEL 304	1/2" ROD
3	NOT REQ.	STAINLESS STEEL 304	2 3/8" X .150 WALL SLEEVE SUPPLIED BY OTHERS

THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION AND OTHER RIGHTS WHICH ARE THE SOLE AND EXCLUSIVE PROPERTY OF MSU MISSISSAUGA LTD.

POSSESSION OF THIS MATERIAL DOES NOT CONVEY OR TRANSFER ANY RIGHTS THEREIN, AND REPRODUCTION, USE, COPYING OR DISCLOSURE TO OTHERS IS FORBIDDEN WITHOUT THE PRIOR WRITTEN CONSENT OF AN OFFICER OF MSU MISSISSAUGA LTD.

© MSU MISSISSAUGA LTD. - JULY 23RD, 2014

WELDING SHALL CONFORM TO CSA W47.1 & AWS D1.6

GUARDRAIL IS DESIGNED PER OBC 4.1.5.15 TO WITHSTAND A HORIZONTAL 0.75KN/M OR 1KN AND A VERTICAL 1.5KN/M ON TOP RAIL NON-COINCIDENT.

PROJECT	LOCATION PROJECT	
CONTRACTOR	CONTRACTOR	
ARCHT./ENGR.	ENGINEER	
QTY.	#	PROJECT NO. #

TITLE						MSU 2" GRIT 180 STAINLESS STEEL DROP IN RAMP RAILING	
NO.	DATE	BY	DATE	DWG. BY	PL. NO.	SCALE	CATA
1			##/##/##	SCJ		NTS	SSRAIL-2